



防爆合格证

证号: GYJ18.1100X

由 Crouse Hinds by EATON COOPER CAPRI SAS
(地址: 36-40 rue des Fontenils Nouan le Fuzelier, France)

制造的产品:

名称 电缆引入装置

型号规格 ADE 系列

防爆标志 Ex d II C Gb Ex e II C Gb Ex nR II C Gc
Ex tD A21 IP66/IP68 Ex d | Mb Ex e | Mb

产品标准 /

图样编号 ADE Rev-1-4

经图样及技术文件的审查和样品检验,确认上述产品符合 GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、GB 3836.8-2014、GB 12476.1-2013、GB 12476.5-2013 标准,特颁发此证。

本证书有效期: 2018年3月27日至2023年3月26日

备注 1. 安全使用注意事项见本证书附件。
2. 证书编号后缀“X”表明产品具有安全使用特殊条件,内容见本证书附件。
3. 型号规格说明见本证书附件。

站长

国家级仪器仪表防爆安全监督检验站

颁发日期二〇一八年三月二十七日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号
邮编: 200233

网址: www.nepsi.org.cn
Email: info@nepsi.org.cn

电话: +86 21 64368180
传真: +86 21 64844580



EXPLOSION PROTECTION

CERTIFICATE OF CONFORMITY

Cert NO.GYJ18.1100X

This is to certify that the product

Cable Gland

manufactured by **Crouse Hinds by EATON COOPER CAPRI SAS**

(Address:36-40 rue des Fontenils Nouan le Fuzelier, France)

which model is **ADE series**

Ex marking **Ex d IIC Gb Ex e IIC Gb Ex nR IIC Gc
Ex tD A21 IP66/IP68 Ex d IMb Ex e IMb**

product standard /

drawing number **ADE Rev-1-4**

has been inspected and certified by NEPSI, and that it conforms
to **GB 3836.1-2010,GB 3836.2-2010,GB 3836.3-2010,GB 3836.8-2014,
GB 12476.1-2013,GB 12476.5-2013**

This Approval shall remain in force until **2023.03.26**

Remarks 1.Conditions for safe use are specified in the attachment(s) to this certificate.
2.Symbol "X" placed after the certification number denotes specific conditions of use,
which are specified in the attachment(s) to this certificate.
3.Model designation is specified in the attachment(s) to this certificate.

Director

National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation

Issued Date **2018.03.27**

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.